

Received as
10/02/15



Jeremiah W. (Jay) Nixon, Governor • Sara Parker Pauley, Director

DEPARTMENT OF NATURAL RESOURCES

www.dnr.mo.gov

September 30, 2015

NOTICE OF VIOLATION

CERTIFIED MAIL #7015 0640 0004 9877 1324

RETURN RECEIPT REQUESTED

City of Bolivar
345 S. Main Avenue
Bolivar, MO 65613

RE: MISSOURI STATE OPERATING PERMIT NUMBER **MO0022373**

Dear Permittee:

A review of your Discharge Monitoring Report(s) (DMR) was conducted by the Department of Natural Resources (department). The monitoring period ending **July 2015** shows that the effluent limitations established in your Missouri State Operating Permit (MSOP) have been exceeded. **This Notice of Violation (NOV)** is being issued for exceedances listed below according to your (MSOP) **MO0022373**. The effluent limits and the values that have exceeded those effluent limits are listed below.

Outfall	Months	Parameter	Permit Limitations	Reported Values
001	07/2015	<i>E.coli</i>	206 MPN/100 mL monthly average	1817 MPN/100 mL
			1030 MPN/100 mL weekly average	1817 MPN/100 mL
001	07/2015	Ammonia as N	1.4 mg/L monthly average	6.16 mg/L
			3.7 mg/L daily max	15 mg/L

An exceedance of the effluent limitations established in your permit is a violation of the Missouri Clean Water Law, Section 644.051.1(3) and 644.076.1, Clean Water Commission Regulation 10 CSR 20-7, and your MSOP. Permittee failed to comply with effluent limits contained in Part "A" of the Missouri State Operating Permit **MO0022373**. Permittee exceeded effluent limitations for *E.coli* and Ammonia as N for the month of **July 2015**. The facility is responsible for taking appropriate steps to eliminate the violation(s).